



SUNSHINE COAST REGIONAL DISTRICT

ADDENDUM NO.2

Request for Proposal No. 18 323

Granthams Landing Community Hall Restoration

Date: February 13, 2019

This addendum forms part of the contract documents and shall be read, interpreted, and coordinated with all other parts. The costs of all work contained herein shall be included in the tender submission. The following revisions, clarifications, changes, additions, or deletions supersede the information contained in the original documents to the extent referenced and shall become part thereof:

Number of pages including attachments: 12

Item No. 1

Question: Is the roof peak (at the front of the building) staying in place and everything else getting lifted? And are we concerned about the hydro connection?

Answer: The roof peak at the front of the building is to remain in place or to be rebuilt to resemble the original roof peak. Regarding the BC Hydro Connection - the contractor to have BC Hydro disconnect the existing service before the building is raised and BC Hydro to then advise as to what upgrades if any are required for the services connection.

Item No. 2

Question: Can you please confirm if the septic field spot is accurate? There appears to be a test drill for a potential water well?

Answer: Replace the onsite wastewater treatment system plan drawings (Page 32 – 42) from Telder Engineering with the attached updated drawings.

Item No.3

Question: We would like to request that our **INTRAGUARD** please be reviewed for alternate approval for sealers.

Answer: INTRAGUARD as approved as an alternate.

Addendum No.2 is issued prior to receipt of submission and shall form part of the contract documents. The revisions shall clarify the information contained in the original Proposal documents issued on January 28, 2019.

If you have any questions regarding the above, please contact the undersigned.

Vanessa Schilling, Buyer
Sunshine Coast Regional District