



SUNSHINE COAST REGIONAL DISTRICT

ADDENDUM NO.3

Request for Quotation No.2137015

Water Services – Pipes, Valves, Fittings, etc.

Date: September 27, 2021

This addendum forms part of the contract documents and shall be read, interpreted, and coordinated with all other parts. The costs of all work contained herein shall be included in the tender submission. The following revisions, clarifications, changes, additions, or deletions supersede the information contained in the original documents to the extent referenced and shall become part thereof:

Number of pages including attachments: 1

Item No.1 Addendum No.2 Item 3 Clarification

Question: Will the SCRD accept bids including a compression style hydrant??

Answer: No, the Regional District requires a slide gate hydrant as per the specifications outlined in the RFQ.

Addendum No.3 is issued prior to receipt of submission and shall form part of the contract documents. The revisions shall clarify the information contained in the original Proposal documents issued on September 17, 2021.

If you have any questions regarding the above, please contact the undersigned.

Vanessa Schilling, Purchasing & Risk Officer
Sunshine Coast Regional District