



SUNSHINE COAST REGIONAL DISTRICT

ADDENDUM NO.5

Request for Quotation No.2137015

Water Services – Pipes, Valves, Fittings, etc.

Date: October 5, 2021

This addendum forms part of the contract documents and shall be read, interpreted, and coordinated with all other parts. The costs of all work contained herein shall be included in the tender submission. The following revisions, clarifications, changes, additions, or deletions supersede the information contained in the original documents to the extent referenced and shall become part thereof:

Number of pages including attachments: 1

Item No.1

Question: What is meant by golden flow pipe? I am assuming this is used for water service tubing? We would normally sell you the standard MST – Municipal Service Tubing. Or there is Ipex Gold901 HDPE. Or there is flowguard which is a CPVC plumbing product.

Answer: HDPE pipes (3/4" and 1" for service connections) confirming to latest AWWA standards

Item No.2

Question: On the product information sheets are you looking for a spec sheet for every item or just something that covers each type of item?

Answer: Product specification sheets must cover each and every single item individually. This may be shown in a table, e.g. Tees, 90°s and 45°s from the same manufacture can be shown in one table.

Item No.3

Question: the below fitting doesn't exist. We would need to make this up with multiple fittings. We can either quote this as N/A or include the price for all the pieces however I don't believe this will be fair when comparing between bidders as who knows what they are including.

6 TYT X 6 TYT X 8 FLG TEE

Answer: We are open for quotations for an assembly with a reducer attachment. So it will be 6TYT*6TYT*6FLG Tee + 6FLG*8FLG Reducer

Item No.4

Question: As current lead times are unprecedented throughout the industry what are you allowing for us to submit in our bid for situations like this. We could put current lead times on there or we could put the normal standard lead times as things should go back to normal I would like to think within the next 3 years.

Answer: Please provide your expected lead times throughout the contract.

Addendum No.5 is issued prior to receipt of submission and shall form part of the contract documents. The revisions shall clarify the information contained in the original Proposal documents issued on September 17, 2021.

If you have any questions regarding the above, please contact the undersigned.

Vanessa Schilling, Purchasing & Risk Officer
Sunshine Coast Regional District