



SUNSHINE COAST REGIONAL DISTRICT

ADDENDUM NO. 2

Request for Proposal No. 2235006

Generators Supply & Installation

Date: April 27, 2022

This addendum forms part of the contract documents and shall be read, interpreted, and coordinated with all other parts. The costs of all work contained herein shall be included in the tender submission. The following revisions, clarifications, changes, additions, or deletions supersede the information contained in the original documents to the extent referenced and shall become part thereof:

Number of pages including attachments: #2

Item No. 1 Section 2.1 b)

Delete "Construct a concrete pad for new generator;"

Add: "Construct a concrete pad for new generator (Sechelt Landfill only);"

Item No. 2 Section 3.3.1

Delete:

"3.3.1 Construct a concrete pad for each generator system

The Contractor will construct a concrete pad for mounting the new generator. It will be constructed in a suitable location as determined by the Contractor and Regional District. The Contractor will be responsible for roughing-in all associated wiring and conduit required for the installation of each new generator with sound reducing enclosure, as determined by the Contractor and the Regional District following review on site."

Add:

"3.3.1 Construct a concrete pad for Sechelt Landfill only

The Contractor will construct a concrete pad for mounting the new generator at the Sechelt Landfill. It will be constructed in a suitable location as determined by the Contractor and Regional District. The Contractor will be responsible for roughing-in all associated wiring and conduit required for the installation of the new generator with sound reducing enclosure, as determined by the Contractor and the Regional District following review on site."

Item No. 3 Section 3.3.2

Delete:

"3.3.2 Supply and install generator cage for each generator system

The Contractor will supply and install a compatible generator cage to protect from unauthorized access, vandalism and theft as determined by the Contractor and the Regional District following site review."

Add:

“3.3.2 Supply and install generator cage/enclosure for each generator system

The Contractor will supply and install a compatible generator cage/enclosure that is lockable, tamper proof to protect from unauthorized access, vandalism and theft as determined by the Contractor and the Regional District following site review.”

Item No. 4 Schedule C Pricing Table

Delete:

Existing Appendix C

Add / Replace

Updated Schedule C

Addendum No. 2 is issued prior to receipt of submission and shall form part of the contract documents. The revisions shall clarify the information contained in the original Proposal documents issued on April 6, 2022.