



SUNSHINE COAST REGIONAL DISTRICT

ADDENDUM NO.# 1

Request for Proposal No. 2261308

Roof Replacement – Bitumen

Date: April 29, 2022

This addendum forms part of the contract documents and shall be read, interpreted, and coordinated with all other parts. The costs of all work contained herein shall be included in the tender submission. The following revisions, clarifications, changes, additions, or deletions supersede the information contained in the original documents to the extent referenced and shall become part thereof:

Number of pages including attachments: #2

Item No. 1 Appendix B Section 11 11 00 Summary of Work 1.19 Waste Management and Disposal

New Item:

.11 The Contractor will be responsible for the removal and disposal of the metal grates along with the existing roof assembly.

Item No. 2 Appendix B Section 07 62 00 Metal Flashing Trim 3.2 Installation

New Item:

.8 Remove and replace the existing vent opening (approx. 26" x 32") within the vertical wall along the north side of the roof shall be repaired by the roof Contractor. This work shall include the installation of a 24 Ga, prefinished metal cover, flashings and sealant material fabricated to accommodate the existing opening and metal cladding.

Item No. 3 Appendix D Bid Form

Delete existing "Appendix D"

Replace with revised "Appendix D"

Addendum No. 1 is issued prior to receipt of submission and shall form part of the contract documents. The revisions shall clarify the information contained in the original Proposal documents issued on April 11, 2022