



SUNSHINE COAST REGIONAL DISTRICT

ADDENDUM NO. # 1

Request for Quotation No. 19 383

Gibsons & District Aquatic Facility Exterior Door Replacement

Date: March 22, 2019

This addendum forms part of the contract documents and shall be read, interpreted, and coordinated with all other parts. The costs of all work contained herein shall be included in the tender submission. The following revisions, clarifications, changes, additions, or deletions supersede the information contained in the original documents to the extent referenced and shall become part thereof:

Number of pages including attachments: 1 page

Addendum # 1 contains responses to questions received by the Regional District about the specifications and instructions in the RFQ, notice to extend the closing date and typo correction.

Item No.1

Question 1

Will the door for the chemical room require a vent?

Answer:

Yes, one vent will be required in the lower portion of the replacement door.

Item No.2

Change closing date for submissions to the RFQ.

The RFQ closing date will be extended from Monday March 25, 2019 3:00 pm local time to Wednesday March 27, 2019 3:00 pm local time.

Item No. 3

Correction typo in title of RFQ.

From: Gibsons District Aquatic Facility Exterior Door Replacement

To: Gibsons & District Aquatic Facility Exterior Door Replacement

Addendum No. # 1 is issued prior to receipt of submission and shall form part of the contract documents. The revisions shall clarify the information contained in the original RFQ documents issued on March 14, 2019.

If you have any questions regarding the above, please contact the undersigned.

Gordon Rischanek - Purchasing Officer
Sunshine Coast Regional District