

Chapman Creek Disinfection By-products (DPB) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Chapman Creek Water System

						GCDWQ ³	
Trihalomethanes	Units	CH-01	CH-11	CH-14	CH-26	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.012	0.042	0.032	0.049		
Bromodichloromethane	mg/L	0.001	0.003	0.002	0.003		
Dibromochloromethane	mg/L	<0.001	<0.001	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.013	0.045	0.033	0.051	0.1⁵	MAC
Haloacetic Acids							
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0	<2.0	2.1		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	4.3	7.9	9.8	8.9		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	4.0	10.6	11.5	10.5		
Total Haloacetic Acids	ug/L	8.3	18.5	21.4	21.5	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

South Pender Disinfection By-products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the South Pender Water System

					GCDWQ ³	
Trihalomethanes	Units	SP-09	SP-03	SP-06	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.035	0.050	0.056		
Bromodichloromethane	mg/L	0.002	0.003	0.003		
Dibromochloromethane	mg/L	<0.001	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.037	0.053	0.059	0.1⁵	MAC
Haloacetic Acids						
Monochloroacetic Acid (MCAA)	ug/L ²	2.4	2.0	2.5		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	10.0	13.9	15.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	10.6	14.8	15.7		
Total Haloacetic Acids	ug/L	23.0	30.7	33.1	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

North Pender Disinfection By-products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the North Pender Water System

				GCDWQ ³	
Trihalomethanes	Units	NP-07	NP-08	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.130	0.023		
Bromodichloromethane	mg/L	0.006	0.002		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.136	0.025	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	3.2	2.4		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	41.4	17.1		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	110.8	13.7		
Total Haloacetic Acids	ug/L	155.4	33.2	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Ruby Lake Disinfection By-Products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Ruby Lake Water System

				GCDWQ ³	
Trihalomethanes	Units	RL-01	RL-03	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.052	0.075		
Bromodichloromethane	mg/L	0.004	0.005		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.056	0.080	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	2.2	2.2		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	19.9	18.5		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	25.1	31.3		
Total Haloacetic Acids	ug/L	47.2	51.9	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Egmont Disinfection By-products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Egmont Water System

				GCDWQ ³	
Trihalomethanes	Units	EG-01	EG-02	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.081	0.123		
Bromodichloromethane	mg/L	0.002	0.003		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.083	0.125	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	2.6	2.9		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	34.7	41.6		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	53.4	87.4		
Total Haloacetic Acids	ug/L	90.6	131.9	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Eastbourne Disinfection By-products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Eastbourne Water System

				GCDWQ ³	
Trihalomethanes	Units	20.1	20.3	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.013	0.031		
Bromodichloromethane	mg/L	0.003	0.004		
Dibromochloromethane	mg/L	0.003	0.004	0.016	MAC
Bromoform	mg/L	<0.001	0.001		
Total Trihalomethanes	mg/L	0.019	0.040	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	2.0		
Bromochloroacetic Acid (BCAA)	ug/L	2.2	2.3		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	2.2	4.3	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Langdale Disinfection By-products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Langdale Water System

				GCDWQ ³	
Trihalomethanes	Units	LA-01	LA-04	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	<0.001	0.001		
Bromodichloromethane	mg/L	<0.001	0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	<0.001	0.002	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	<12.0	<12.0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Granthams Disinfection By-products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Granthams Water System

				GCDWQ ³	
Trihalomethanes	Units	GL-01	GL-02	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	<0.001	<0.001		
Bromodichloromethane	mg/L	<0.001	<0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	<0.001	<0.001	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	<12.0	<12.0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Soames Disinfection By Products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Soames Water System

				GCDWQ ³	
Trihalomethanes	Units	SO-01	SO-03	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	<0.001	<0.001		
Bromodichloromethane	mg/L	<0.001	<0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	<0.001	<0.001	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	<12.0	<12.0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Chaster Well Disinfection By Products (DBP) Test Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Chaster Well Water System

			GCDWQ ³	
Trihalomethanes	Units	CW-01	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	<0.001		
Bromodichloromethane	mg/L	<0.001		
Dibromochloromethane	mg/L	<0.001	0.016	MAC
Bromoform	mg/L	<0.001		
Total Trihalomethanes	mg/L	<0.001	0.1⁵	MAC
Haloacetic Acids				
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0		
Total Haloacetic Acids	ug/L	<12.0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Katherine Lake Disinfection By Products Test (DBP) Results

2021 Third Quarter Running Annual Average Results

Samples collected from the Katherine Lake Water System

			GCDWQ ³	
Trihalomethanes	Units	KA-01	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.002		
Bromodichloromethane	mg/L	0.001		
Dibromochloromethane	mg/L	<0.001	0.016	MAC
Bromoform	mg/L	<0.001		
Total Trihalomethanes	mg/L	0.003	0.1⁵	MAC
Haloacetic Acids				
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0		
Total Haloacetic Acids	ug/L	<12.0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average