

Chapman Creek Disinfection By-products (DPB) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Chapman Creek Water System

						GCDWQ ³	
Trihalomethanes	Units	CH-01	CH-11	CH-14	CH-26	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.004	0.084	0.087	0.051		
Bromodichloromethane	mg/L	<0.001	0.001	0.001	0.003		
Dibromochloromethane	mg/L	<0.001	<0.001	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.004	0.085	0.088	0.054	0.1⁵	MAC
Haloacetic Acids							
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	2.8	25.7	24.7	6.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	40.7	44.3	7.8		
Total Haloacetic Acids	ug/L	2.8	66.4	69.0	13.8	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

South Pender Disinfection By-products (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the South Pender Water System

					GCDWQ ³	
Trihalomethanes	Units	SP-09	SP-03	SP-06	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.063	0.080	0.091		
Bromodichloromethane	mg/L	0.004	0.005	0.005		
Dibromochloromethane	mg/L	<0.001	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.067	0.085	0.096	0.1⁵	MAC
Haloacetic Acids						
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	14.5	19.0	20.9		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	14.3	20.2	20.0		
Total Haloacetic Acids	ug/L	28.8	39.2	40.9	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

North Pender Disinfection By-prodcuts (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the North Pender Water System

				GCDWQ ³	
Trihalomethanes	Units	NP-07	NP-08	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.122	0.013		
Bromodichloromethane	mg/L	0.007	<0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.129	0.013	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	36	13		
Bromochloroacetic Acid (BCAA)	ug/L	3	3		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	77	7		
Total Haloacetic Acids	ug/L	115.8	22.8	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Ruby Lake Disinfection By-Products (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Ruby Lake Water System

				GCDWQ ³	
Trihalomethanes	Units	RL-01	RL-03	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.078	0.111		
Bromodichloromethane	mg/L	0.006	0.007		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.084	0.118	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	21	23		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	29	31		
Total Haloacetic Acids	ug/L	49.9	53.4	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Egmont Disinfection By-products (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Egmont Water System

				GCDWQ ³	
Trihalomethanes	Units	EG-01	EG-02	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.086	0.132		
Bromodichloromethane	mg/L	0.002	0.003		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.088	0.135	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	23	32		
Bromochloroacetic Acid (BCAA)	ug/L	2	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	39	78		
Total Haloacetic Acids	ug/L	63.8	109.1	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Eastbourne Disinfection By-products (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Eastbourne Water System

				GCDWQ ³	
Trihalomethanes	Units	20.1	20.3	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.003	0.003		
Bromodichloromethane	mg/L	0.004	0.005		
Dibromochloromethane	mg/L	0.004	0.005	0.016	MAC
Bromoform	mg/L	0.001	0.002		
Total Trihalomethanes	mg/L	0.012	0.015	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	2.0	2.2		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	2	2.2	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Langdale Disinfection By-products (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Langdale Water System

				GCDWQ ³	
Trihalomethanes	Units	LA-01	LA-04	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	<0.001	0.002		
Bromodichloromethane	mg/L	<0.001	0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.000	0.003	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	0	0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Granthams Disinfection By-products (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Granthams Water System

				GCDWQ ³	
Trihalomethanes	Units	GL-01	GL-02	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	<0.001	<0.001		
Bromodichloromethane	mg/L	<0.001	<0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.000	0.000	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	0	0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Soames Disinfection By Products (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Soames Water System

				GCDWQ ³	
Trihalomethanes	Units	SO-01	SO-03	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	<0.001	0.001		
Bromodichloromethane	mg/L	<0.001	<0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.000	0.001	0.1⁵	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	0	0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Chaster Well Disinfection By Products (DBP) Test Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Chaster Well Water System

Trihalomethanes	Units	CW-01	GCDWQ ³	
			Limits	AO/MAC ⁴
Chloroform	mg/L ¹	<0.001		
Bromodichloromethane	mg/L	<0.001		
Dibromochloromethane	mg/L	<0.001	0.016	MAC
Bromoform	mg/L	<0.001		
Total Trihalomethanes	mg/L	0.000	0.1⁵	MAC
Haloacetic Acids				
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0		
Total Haloacetic Acids	ug/L	0	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average

Katherine Lake Disinfection By Products Test (DBP) Results

2019 Third Quarter Running Annual Average Results

Samples collected from the Katherine Lake Water System

			GCDWQ ³	
Trihalomethanes	Units	KA-01	Limits	AO/MAC ⁴
Chloroform	mg/L ¹	0.004		
Bromodichloromethane	mg/L	0.003		
Dibromochloromethane	mg/L	0.001	0.016	MAC
Bromoform	mg/L	<0.001		
Total Trihalomethanes	mg/L	0.008	0.1⁵	MAC
Haloacetic Acids				
Monochloroacetic Acid (MCAA)	ug/L ²	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	2.3		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0		
Total Haloacetic Acids	ug/L	2.3	80⁵	MAC

1 - milligrams per litre (parts per million)

2 - micrograms per litre (parts per billion)

3 - Guidelines for Canadian Drinking Water Quality

4 - AO/MAC (Aesthetic Objective / Maximum Acceptable Concentration)

5 - Expressed as a running annual average