

## Chapman Creek Water Potability Test Results

Date: March 11, 2020

Sample collected for Chapman Creek Water System

PARAMETERS	UNITS	CH-26	GCDWQ <sup>2</sup>	
				OG/AO/MAC
<b>Anions</b>				
Chloride	mg/L <sup>1</sup>	9.08	<b>250</b>	AO
Fluoride	mg/L	<0.01	<b>1.5</b>	MAC
Nitrate (as N)	mg/L	0.04	<b>10</b>	MAC
Nitrite (as N)	mg/L	<0.01	<b>1</b>	MAC
Sulfate	mg/L	1	<b>500</b>	AO
<b>Calculated Parameters</b>				
Hardness, Total (as CaCO <sub>3</sub> )	mg/L	7.7		
<b>General Parameters</b>				
Colour, True	TCU	<5	<b>15</b>	AO
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	24		
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	mg/L	<5		
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	mg/L	29		
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	mg/L	<6		
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	mg/L	<5		
Phosphorus, Total (as P)	mg/L	0.003		
Solids, Total Dissolved	mg/L	56	<b>500</b>	AO
Turbidity	NTU	0.67	<b>5</b>	MAC
pH	pH units	7.51	<b>7.0-10.5</b>	OG
<b>Total Metals</b>				
Aluminum, total	mg/L	0.027	<b>0.2</b>	OG
Antimony, total	mg/L	<0.0002	<b>0.006</b>	MAC
Arsenic, total	mg/L	<0.0001	<b>0.01</b>	MAC
Barium, total	mg/L	0.0002	<b>1</b>	MAC
Beryllium, total	mg/L	<0.0005		
Bismuth, total	mg/L	<0.0001		
Boron, total	mg/L	<0.01	<b>5</b>	AO
Cadmium, total	mg/L	<0.00001	<b>0.005</b>	MAC
Calcium, total	mg/L	0.0027		
Chromium, total	mg/L	<0.0002	<b>0.05</b>	MAC
Cobalt, total	mg/L	<0.0002		
Copper, total	mg/L	0.0071	<b>1</b>	AO
Iron, total	mg/L	0.13	<b>0.3</b>	AO
Lead, total	mg/L	0.0005	<b>0.01</b>	MAC
Lithium, total	mg/L	<0.0005		
Magnesium, total	mg/L	0.0021		
Manganese, total	mg/L	0.001	<b>0.05</b>	AO
Mercury, total	mg/L	<0.0001	<b>0.001</b>	MAC
Molybdenum, total	mg/L	0.0001		
Nickel, total	mg/L	0.0009		
Phosphorus, total	mg/L	0.003		

## Chapman Creek Water Potability Test Results

Date: March 11, 2020

Sample collected for Chapman Creek Water System

<b>Total Metals-continued</b>	<b>UNITS</b>	<b>CH-26</b>	<b>GCDWQ<sup>2</sup></b>	
Potassium, total	mg/L	0.14		
Selenium, total	mg/L	<0.2	<b>0.05</b>	MAC
Silicon, total	mg/L	2.0		
Silver, total	mg/L	0.02		
Sodium, total	mg/L	11.0	<b>200</b>	AO
Strontium, total	mg/L	9.70		
Sulfur, total	mg/L	0.33		
Thallium, total	mg/L	<0.01		
Thorium, total	mg/L	<0.05		
Tin, total	mg/L	<0.1		
Titanium, total	mg/L	<0.002		
Uranium, total	mg/L	<0.01	<b>0.02</b>	MAC
Vanadium, total	mg/L	0.6		
Zinc, total	mg/L	3.0	<b>5</b>	AO
Zirconium, total	mg/L	<0.1		
<b>Volatile Organic Compounds (VOC)</b>				
Benzene	mg/L	<0.0005	<b>0.005</b>	MAC
Ethylbenzene	mg/L	<0.0005	<b>0.14</b>	MAC
Methyl tert-butyl ether	mg/L	<0.0005	<b>0.015</b>	AO
Styrene	mg/L	<0.0005		
Toluene	mg/L	<0.0005	<b>0.06</b>	MAC
Xylenes (total)	mg/L	<0.0005	<b>0.09</b>	AO

1 - milligrams per litre (parts per million)

2 - Guidelines for Canadian Drinking Water Quality

### Acronyms

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units

## South Pender Water Potability Test Results

Date: March 11, 2020

Sample collected for South Pender Water System

PARAMETERS	UNITS	SP-03	GCDWQ <sup>3</sup>	
				OG/AO/MAC
<b>Anions</b>				
Chloride	mg/L <sup>1</sup>	6.41	<b>250</b>	AO
Fluoride	mg/L	<0.01	<b>1.5</b>	MAC
Nitrate (as N)	mg/L	<0.01	<b>10</b>	MAC
Nitrite (as N)	mg/L	<0.01	<b>1</b>	MAC
Sulfate	mg/L	1.3	<b>500</b>	AO
<b>Calculated Parameters</b>				
Hardness, Total (as CaCO <sub>3</sub> )	mg/L	7.4		
<b>General Parameters</b>				
Colour, True	TCU	<5.0	<b>15</b>	AO
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	23		
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	mg/L	<5		
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	mg/L	28		
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	mg/L	<6		
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	mg/L	<5		
Phosphorus, Total (as P)	mg/L	0.004		
Solids, Total Dissolved	mg/L	38	<b>500</b>	AO
Turbidity	NTU	<0.10	<b>5</b>	MAC
pH	pH units	7.32	<b>7.0-10.5</b>	OG
Conductivity	µS/cm <sup>2</sup>	65		
<b>Total Metals</b>				
Aluminum, total	mg/L	0.0220	<b>0.2</b>	OG
Antimony, total	mg/L	<0.00002	<b>0.006</b>	MAC
Arsenic, total	mg/L	0.0002	<b>0.01</b>	MAC
Barium, total	mg/L	0.0022	<b>1</b>	MAC
Beryllium, total	mg/L	<0.00005		
Bismuth, total	mg/L	<0.0001		
Boron, total	mg/L	0.005	<b>5</b>	AO
Cadmium, total	mg/L	<0.00001	<b>0.005</b>	MAC
Calcium, total	mg/L	0.0024		
Chromium, total	mg/L	<0.00005	<b>0.05</b>	MAC
Cobalt, total	mg/L	<0.00002		
Copper, total	mg/L	0.001	<b>1</b>	AO
Iron, total	mg/L	0.007	<b>0.3</b>	AO
Lead, total	mg/L	0.00002	<b>0.01</b>	MAC
Lithium, total	mg/L	<0.0005		
Magnesium, total	mg/L	0.33		
Manganese, total	mg/L	<0.001	<b>0.05</b>	AO
Mercury, total	mg/L	<0.00001	<b>0.001</b>	MAC
Molybdenum, total	mg/L	0.0016		
Nickel, total	mg/L	0.0012		
Phosphorus, total	mg/L	0.0004		

## South Pender Water Potability Test Results

Date: March 11, 2020

Sample collected for South Pender Water System

Total Metals-continued	UNITS	SP-03	GCDWQ <sup>3</sup>	
Potassium, total	mg/L	0.20		
Selenium, total	mg/L	<0.0002	<b>0.05</b>	MAC
Silicon, total	mg/L	3.10		
Silver, total	mg/L	<0.00001		
Sodium, total	mg/L	10	<b>200</b>	AO
Strontium, total	mg/L	0.013		
Sulfur, total	mg/L	0.43		
Tellurium, total	mg/L			
Thallium, total	mg/L	<0.00001		
Thorium, total	mg/L	<0.00005		
Tin, total	mg/L	<0.0001		
Titanium, total	mg/L	<0.002		
Uranium, total	mg/L	<0.00001	<b>0.02</b>	MAC
Vanadium, total	mg/L	0.00037		
Zinc, total	mg/L	0.0033	<b>5</b>	AO
Zirconium, total	mg/L	<0.0001		
<b>Volatile Organic Compounds (VOC)</b>				
Benzene	mg/L	<0.0005	<b>0.005</b>	MAC
Ethylbenzene	mg/L	<0.0005	<b>0.14</b>	MAC
Methyl tert-butyl ether	mg/L	<0.0005	<b>0.015</b>	AO
Styrene	mg/L	<0.0005		
Toluene	mg/L	<0.0005	<b>0.06</b>	MAC
Xylenes (total)	mg/L	<0.0005	<b>0.09</b>	AO

1 - milligrams per litre (parts per million)

2 - microsiemens per centimeter

3 - Guidelines for Canadian Drinking Water Quality

### Acronyms

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units

## North Pender Water Potability Test Results

Date: March 10, 2020

Sample collected for North Pender Water System

PARAMETERS	UNITS	NP-07	GCDWQ <sup>2</sup>	
				OG/AO/MAC
<b>Anions</b>				
Chloride	mg/L <sup>1</sup>	10.7	<b>250</b>	AO
Fluoride	mg/L	<0.01	<b>1.5</b>	MAC
Nitrate (as N)	mg/L	0.04	<b>10</b>	MAC
Nitrite (as N)	mg/L	<0.01	<b>1</b>	MAC
Sulfate	mg/L	2.8	<b>500</b>	AO
<b>Calculated Parameters</b>				
Hardness, Total (as CaCO <sub>3</sub> )	mg/L	16		
<b>General Parameters</b>				
Colour, True	TCU	<5	<b>15</b>	AO
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	20		
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	mg/L	<5		
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	mg/L	25		
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	mg/L	<6		
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	mg/L	<5		
Phosphorus, Total (as P)	mg/L	0.021		
Solids, Total Dissolved	mg/L	72	<b>500</b>	AO
Turbidity	NTU	0.23	<b>5</b>	MAC
pH	pH units	7.2	<b>7.0-10.5</b>	OG
<b>Total Metals</b>				
Aluminum, total	mg/L	0.015	<b>0.2</b>	OG
Antimony, total	mg/L	0.00002	<b>0.006</b>	MAC
Arsenic, total	mg/L	0.0002	<b>0.01</b>	MAC
Barium, total	mg/L	0.0024	<b>1</b>	MAC
Beryllium, total	mg/L	<0.00005		
Bismuth, total	mg/L	<0.0001		
Boron, total	mg/L	0.008	<b>5</b>	AO
Cadmium, total	mg/L	<0.00001	<b>0.005</b>	MAC
Calcium, total	mg/L	0.005		
Chromium, total	mg/L	0.00007	<b>0.05</b>	MAC
Cobalt, total	mg/L	<0.00002		
Copper, total	mg/L	0.0025	<b>1</b>	AO
Iron, total	mg/L	0.078	<b>0.3</b>	AO
Lead, total	mg/L	0.00009	<b>0.01</b>	MAC
Lithium, total	mg/L	<0.0005		
Magnesium, total	mg/L	0.00079		
Manganese, total	mg/L	0.003	<b>0.05</b>	AO
Mercury, total	mg/L	<0.00001	<b>0.001</b>	MAC
Molybdenum, total	mg/L	0.0015		
Nickel, total	mg/L	0.0009		
Phosphorus, total	mg/L	0.000021		

## North Pender Water Potability Test Results

Date: March 10, 2020

Sample collected for North Pender Water System

Total Metals-continued	UNITS	NP-07	GCDWQ <sup>2</sup>	
Potassium, total	mg/L	0.55		
Selenium, total	mg/L	<0.0002	<b>0.05</b>	MAC
Silicon, total	mg/L	2.40		
Silver, total	mg/L	<0.00001		
Sodium, total	mg/L	8.2	<b>200</b>	AO
Strontium, total	mg/L	0.0023		
Sulfur, total	mg/L	0.90		
Thallium, total	mg/L	<0.00001		
Thorium, total	mg/L	<0.00005		
Tin, total	mg/L	<0.0001		
Titanium, total	mg/L	<0.002		
Uranium, total	mg/L	0.00002	<b>0.02</b>	MAC
Vanadium, total	mg/L	0.00023		
Zinc, total	mg/L	0.007	<b>5</b>	AO
Zirconium, total	mg/L	<0.0001		
<b>Volatile Organic Compounds (VOC)</b>				
Benzene	mg/L	<0.0005	<b>0.005</b>	MAC
Ethylbenzene	mg/L	<0.0005	<b>0.14</b>	MAC
Methyl tert-butyl ether	mg/L	<0.0005	<b>0.015</b>	AO
Styrene	mg/L	<0.0005		
Toluene	mg/L	<0.0005	<b>0.06</b>	MAC
Xylenes (total)	mg/L	<0.0005	<b>0.09</b>	AO

1 - milligrams per litre (parts per million)

2 - Guidelines for Canadian Drinking Water Quality

### Acronyms

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units

## Ruby Lake Water Potability Test Results

Date: March 9, 2020

Sample collected for Ruby Lake Water System

PARAMETERS	UNITS	RL-03	GCDWQ <sup>2</sup>	
<b>Anions</b>				<b>OG/AO/MAC</b>
Chloride	mg/L <sup>1</sup>	6.51	<b>250</b>	AO
Fluoride	mg/L	<0.01	<b>1.5</b>	MAC
Nitrate (as N)	mg/L	0.01	<b>10</b>	MAC
Nitrite (as N)	mg/L	<0.01	<b>1</b>	MAC
Sulfate	mg/L	2.1	<b>500</b>	AO
<b>Calculated Parameters</b>				
Hardness, Total (as CaCO <sub>3</sub> )	mg/L	19		
<b>General Parameters</b>				
Colour, True	TCU	<5.0	<b>15</b>	AO
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	21		
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	mg/L	<5		
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	mg/L	26		
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	mg/L	<6		
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	mg/L	<5		
Phosphorus, Total (as P)	mg/L	0.005		
Solids, Total Dissolved	mg/L	10	<b>500</b>	AO
Turbidity	NTU	0.33	<b>5</b>	MAC
pH	pH units	8.1	<b>7.0-10.5</b>	OG
<b>Total Metals</b>				
Aluminum, total	mg/L	0.005	<b>0.2</b>	OG
Antimony, total	mg/L	<0.00003	<b>0.006</b>	MAC
Arsenic, total	mg/L	0.0004	<b>0.01</b>	MAC
Barium, total	mg/L	0.003	<b>1</b>	MAC
Beryllium, total	mg/L	<0.00005		
Bismuth, total	mg/L	<0.0001		
Boron, total	mg/L	0.007	<b>5</b>	AO
Cadmium, total	mg/L	<0.00001	<b>0.005</b>	MAC
Calcium, total	mg/L	6.70		
Chromium, total	mg/L	<0.00005	<b>0.05</b>	MAC
Cobalt, total	mg/L	<0.00002		
Copper, total	mg/L	0.0016	<b>1</b>	AO
Iron, total	mg/L	0.13	<b>0.3</b>	AO
Lead, total	mg/L	0.0001	<b>0.01</b>	MAC
Lithium, total	mg/L	<0.0005		
Magnesium, total	mg/L	0.60		
Manganese, total	mg/L	0.002	<b>0.05</b>	AO
Mercury, total	mg/L	<0.0001	<b>0.001</b>	MAC
Molybdenum, total	mg/L	0.00042		
Nickel, total	mg/L	0.0006		
Phosphorus, total	mg/L	0.005		

## Ruby Lake Water Potability Test Results

Date: March 9, 2020

Sample collected for Ruby Lake Water System

Total Metals-continued	UNITS	RL-03	GCDWQ <sup>2</sup>	
Potassium, total	mg/L	0.32		
Selenium, total	mg/L	<0.0002	<b>0.05</b>	MAC
Silicon, total	mg/L	1.30		
Silver, total	mg/L	<0.00001		
Sodium, total	mg/L	5.2	<b>200</b>	AO
Strontium, total	mg/L	0.016		
Sulfur, total	mg/L	0.79		
Thallium, total	mg/L	<0.00001		
Thorium, total	mg/L	0.00012		
Tin, total	mg/L	<0.0001		
Titanium, total	mg/L	<0.002		
Uranium, total	mg/L	0.00001	<b>0.02</b>	MAC
Vanadium, total	mg/L	0.0004		
Zinc, total	mg/L	0.0091	<b>5</b>	AO
Zirconium, total	mg/L	0.0001		
<b>Volatile Organic Compounds (VOC)</b>				
Benzene	mg/L	<0.0005	<b>0.005</b>	MAC
Ethylbenzene	mg/L	<0.0005	<b>0.14</b>	MAC
Methyl tert-butyl ether	mg/L	<0.0005	<b>0.015</b>	AO
Styrene	mg/L	<0.0005		
Toluene	mg/L	<0.0005	<b>0.06</b>	MAC
Xylenes (total)	mg/L	<0.0005	<b>0.09</b>	AO

1 - milligrams per litre (parts per million)

2 - Guidelines for Canadian Drinking Water Quality

### Acronyms

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units



## Egmont Water Potability Test Results

Date: March 9, 2020

Sample collected for Egmont Water System

PARAMETERS	UNITS	EG-02	GCDWQ <sup>2</sup>	
<b>Anions</b>				<b>OG/AO/MAC</b>
Chloride	mg/L <sup>1</sup>	4.41	<b>250</b>	AO
Fluoride	mg/L	<0.01	<b>1.5</b>	MAC
Nitrate (as N)	mg/L	0.04	<b>10</b>	MAC
Nitrite (as N)	mg/L	<0.01	<b>1</b>	MAC
Sulfate	mg/L	1.2	<b>500</b>	AO
<b>Calculated Parameters</b>				
Hardness, Total (as CaCO <sub>3</sub> )	mg/L	11		
<b>General Parameters</b>				
Colour, True	TCU	<5.0	<b>15</b>	AO
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	11		
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	mg/L	<5		
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	mg/L	13		
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	mg/L	<6		
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	mg/L	<5		
Phosphorus, Total (as P)	mg/L	0.004		
Solids, Total Dissolved	mg/L	10	<b>500</b>	AO
Turbidity	NTU	0.2	<b>5</b>	MAC
pH	pH units	7.02	<b>7.0-10.5</b>	OG
<b>Total Metals</b>				
Aluminum, total	mg/L	0.019	<b>0.2</b>	OG
Antimony, total	mg/L	<0.00002	<b>0.006</b>	MAC
Arsenic, total	mg/L	0.0002	<b>0.01</b>	MAC
Barium, total	mg/L	0.0027	<b>1</b>	MAC
Beryllium, total	mg/L	<0.00005		
Bismuth, total	mg/L	<0.0001		
Boron, total	mg/L	0.003	<b>5</b>	AO
Cadmium, total	mg/L	<0.00001	<b>0.005</b>	MAC
Calcium, total	mg/L	3.80		
Chromium, total	mg/L	<0.00005	<b>0.05</b>	MAC
Cobalt, total	mg/L	<0.00002		
Copper, total	mg/L	0.0064	<b>1</b>	AO
Iron, total	mg/L	0.08	<b>0.3</b>	AO
Lead, total	mg/L	0.0001	<b>0.01</b>	MAC
Lithium, total	mg/L	<0.0005		
Magnesium, total	mg/L	0.36		
Manganese, total	mg/L	0.002	<b>0.05</b>	AO
Mercury, total	mg/L	<0.00001	<b>0.001</b>	MAC
Molybdenum, total	mg/L	0.0004		
Nickel, total	mg/L	<0.0002		
Phosphorus, total	mg/L	0.004		

## Egmont Water Potability Test Results

Date: March 9, 2020

Sample collected for Egmont Water System

Total Metals-continued	UNITS	EG-02	GCDWQ <sup>2</sup>	
Potassium, total	mg/L	0.17		
Selenium, total	mg/L	<0.0002	<b>0.05</b>	MAC
Silicon, total	mg/L	1.80		
Silver, total	mg/L	<0.0001		
Sodium, total	mg/L	3.90	<b>200</b>	AO
Strontium, total	mg/L	0.012		
Sulfur, total	mg/L	0.47		
Thallium, total	mg/L	<0.00001		
Thorium, total	mg/L	<0.00013		
Tin, total	mg/L	<0.0001		
Titanium, total	mg/L	<0.002		
Uranium, total	mg/L	0.00001	<b>0.02</b>	MAC
Vanadium, total	mg/L	0.0007		
Zinc, total	mg/L	0.017	<b>5</b>	AO
Zirconium, total	mg/L	0.0001		
<b>Volatile Organic Compounds (VOC)</b>				
Benzene	mg/L	<0.0005	<b>0.005</b>	MAC
Ethylbenzene	mg/L	<0.0005	<b>0.14</b>	MAC
Methyl tert-butyl ether	mg/L	<0.0005	<b>0.015</b>	AO
Styrene	mg/L	<0.0005		
Toluene	mg/L	<0.0005	<b>0.06</b>	MAC
Xylenes (total)	mg/L	<0.0005	<b>0.09</b>	AO

1 - milligrams per litre (parts per million)

2 - Guidelines for Canadian Drinking Water Quality

### Acronyms

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units

## Eastbourne Water Potability Test Results

Date: March 11, 2020

Sample collected for Eastbourne Water System

Parameters	Units	20.3	GCDWQ <sup>3</sup>	
<b>Aggregate Organic Constituents</b>				OG/AO/MAC
Chemical Oxygen Demand	mg/L <sup>1</sup>	<10		
<b>Inorganic Nonmetallic Parameters</b>				
Kjeldahl Nitrogen	mg/L	0.3		
Organic Carbon	mg/L	<0.5		
Ammonia - N	mg/L	<0.01		
Phosphorus	mg/L	0.008		
<b>Metals Dissolved</b>				
Mercury	µg/L <sup>4</sup>	<0.01	0.001	MAC
<b>Physical and Aggregate Properties</b>				
Turbidity	NTU	<0.10	5	MAC
<b>Routine Water</b>				
pH	pH units	7.23	7.0-10.5	OG
Conductivity	µS/cm <sup>2</sup>	112		
Calcium	mg/L	4.5		
Magnesium	mg/L	1.5		
Potassium	mg/L	0.71		
Sodium	mg/L	13	200	AO
Sulfur	mg/L	1.9		
Bicarbonate	mg/L	39		
Carbonate	mg/L	<6		
Hydroxide	mg/L	<5		
P-Alkalinity	mg/L	<5		
T-Alkalinity	mg/L	32		
Chloride	mg/L	9.01	250	AO
Nitrate - N	mg/L	0.65	10	MAC
Nitrite - N	mg/L	<0.01	1	MAC
Sulfate (SO <sub>4</sub> )	mg/L	6.1	500	AO
Hardness	mg/L	17		
Salinity	g/L <sup>5</sup>	0.033		
Silicon	µg/L	7600		
<b>Mono-Aromatic Hydrocarbons - Water</b>				
Benzene	mg/L	<0.0005	0.005	MAC
Ethylbenzene	mg/L	<0.0005	0.14	MAC
Methyl t-Butyl Ether	mg/L	<0.0005	0.015	AO
Styrene	mg/L	<0.0005		
Toluene	mg/L	<0.0005	0.06	MAC
Total Xylenes (m,p,o)	mg/L	<0.0005	0.09	MAC
4-Bromofluorobenzene	%	113		
Dibromofluoromethane	%	116		
Toluene-d <sub>8</sub>	%	106		

## Eastbourne Water Potability Test Results

Date: March 11, 2020

Sample collected for Eastbourne Water System

<b>Volatile Petroleum Hydrocarbons - Water</b>				
VPHw (VHw6-10 minus BTEX)	µg/L	<50		
VHw6-10	µg/L	<50		
<b>VOC - Water - Surrogate Recovery</b>				
Dibromofluoromethane	%	116		
Toluene-d8	%	106		
Bromofluorobenzene	%	113		
<b>Trace Metals Dissolved</b>				
Aluminum	mg/L	0.015	<b>0.2</b>	OG
Antimony	mg/L	0.00005	<b>0.006</b>	MAC
Arsenic	mg/L	0.001	<b>0.01</b>	MAC
Barium	mg/L	0.0131	<b>2</b>	MAC
Beryllium	mg/L	<0.00005		
Bismuth	mg/L	<0.0001		
Boron	mg/L	0.044	<b>5</b>	AO
Cadmium	mg/L	<0.00001	<b>0.007</b>	MAC
Chromium	mg/L	<0.00005	<b>0.05</b>	MAC
Cobalt	mg/L	0.00004		
Copper	mg/L	0.0528	<b>2</b>	AO
Iron	mg/L	0.008	<b>0.3</b>	AO
Lead	mg/L	0.00085	<b>0.005</b>	MAC
Lithium	mg/L	0.0007		
Manganese	mg/L	<0.001	<b>0.12</b>	AO
Molybdenum	mg/L	0.00022		
Nickel	mg/L	0.0009		
Selenium	mg/L	<0.0002	<b>0.05</b>	MAC
Silver	mg/L	<0.00001		
Strontium	mg/L	0.0461	<b>7</b>	MAC
Thallium	mg/L	<0.00001		
Thorium	mg/L	<0.00005		
Tin	mg/L	0.0024		
Uranium	mg/L	<0.00001	<b>0.02</b>	MAC
Vanadium	mg/L	0.00049		
Zinc	mg/L	0.0159	<b>5</b>	AO
Zirconium	mg/L	<0.0001		
Titanium	mg/L	<0.0001		

1 - milligrams per litre (parts per million)

2 - microsiemens per centimeter

3 - Guidelines for Canadian Drinking Water Quality

4 - micrograms per litre (parts per billion)

5 - grams per litre

**Acronyms**

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units

## Langdale Water Potability Test Results

Date: March 11, 2020

Sample collected in the Langdale Water System

PARAMETERS	UNITS	LA-04	GCDWQ <sup>3</sup>	
<b>Anions</b>				OG/AO/MAC
Chloride	mg/L <sup>1</sup>	3.12	<b>250</b>	AO
Nitrate (as N)	mg/L	0.23	<b>10</b>	MAC
Nitrite (as N)	mg/L	<0.01	<b>1</b>	MAC
Sulfate	mg/L	10.9	<b>500</b>	MAC
<b>BCMOE Aggregate Hydrocarbons</b>				
VHw (6-10)	ug/L <sup>4</sup>	<50		
VPHw	ug/L	<50		
<b>General Parameters</b>				
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	39		
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	mg/L	<5		
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	mg/L	48		
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	mg/L	<6		
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	mg/L	<5		
Ammonia, Total (as N)	mg/L	0.04		
Carbon, Dissolved Organic	mg/L	<0.5		
Chemical Oxygen Demand	mg/L	10		
Nitrogen, Total Kjeldahl	mg/L	<0.07		
Conductivity	µS/cm <sup>2</sup>	115		
<b>Volatile Organic Compounds (VOC)</b>				
Benzene	mg/L	<0.0005	<b>0.005</b>	MAC
Ethylbenzene	mg/L	<0.0005	<b>0.14</b>	MAC
Methyl tert-butyl ether	mg/L	<0.0005	<b>0.015</b>	AO
Styrene	mg/L	<0.0005		
Xylenes (total)	mg/L	<0.0005	<b>0.09</b>	MAC

1 - milligrams per litre (parts per million)

2 - microsiemens per centimeter

3 - Guidelines for Canadian Drinking Water Quality

4 - micrograms per litre (parts per billion)

### Acronyms

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units

## Soames Water Potability Test Results

Date: March 11, 2020

Sample collected in the Soames Water System

PARAMETERS	UNITS	SO - 03	GCDWQ <sup>3</sup>	
<b>Anions</b>				OG/AO/MAC
Chloride	mg/L <sup>1</sup>	5.72	<b>250</b>	AO
Nitrate (as N)	mg/L	0.62	<b>10</b>	MAC
Nitrite (as N)	mg/L	<0.01	<b>1</b>	MAC
Sulfate	mg/L	8.4	<b>500</b>	AO
<b>BCMOE Aggregate Hydrocarbons</b>				
VHw (6-10)	ug/L <sup>4</sup>	<50		
VPHw	ug/L	<50		
<b>General Parameters</b>				
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	48		
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	mg/L	<5		
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	mg/L	58		
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	mg/L	<6		
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	mg/L	<5		
Ammonia, Total (as N)	mg/L	0.01		
Carbon, Dissolved Organic	mg/L	<0.5		
Chemical Oxygen Demand	mg/L	<10		
Nitrogen, Total Kjeldahl	mg/L	0.08		
Conductivity	μS/cm <sup>2</sup>	136		
<b>Volatile Organic Compounds (VOC)</b>				
Benzene	mg/L	<0.0005	<b>0.005</b>	MAC
Ethylbenzene	mg/L	<0.0005	<b>0.14</b>	MAC
Methyl tert-butyl ether	mg/L	<0.0005	<b>0.015</b>	AO
Styrene	mg/L	<0.0005		
Xylenes (total)	mg/L	<0.0005	<b>0.09</b>	MAC

1 - milligrams per litre (parts per million)

2 - microsiemens per centimeter

3 - Guidelines for Canadian Drinking Water Quality

4 - micrograms per litre (parts per billion)

### Acronyms

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units

## Granthams Water Potability Test Results

Date: March 13, 2020

Sample collected in the Granthams Water System

PARAMETERS	UNITS	GL - 02	GCDWQ <sup>3</sup>	
<b>Anions</b>				OG/AO/MAC
Chloride	mg/L <sup>1</sup>	4.48	<b>250</b>	AO
Nitrate (as N)	mg/L	0.44	<b>10</b>	MAC
Nitrite (as N)	mg/L	<0.01	<b>1</b>	MAC
Sulfate	mg/L	8.4	<b>500</b>	MAC
<b>BCMOE Aggregate Hydrocarbons</b>				
VHw (6-10)	ug/L <sup>4</sup>	<50		
VPHw	ug/L	<50		
<b>General Parameters</b>				
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	43		
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	mg/L	<5		
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	mg/L	52		
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	mg/L	<6		
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	mg/L	<5		
Ammonia, Total (as N)	mg/L	0.02		
Carbon, Dissolved Organic	mg/L	<0.5		
Chemical Oxygen Demand	mg/L	<10		
Nitrogen, Total Kjeldahl	mg/L	<0.07		
Conductivity	μS/cm <sup>2</sup>	121		
<b>Volatile Organic Compounds (VOC)</b>				
Benzene	mg/L	<0.0005	<b>0.005</b>	MAC
Ethylbenzene	mg/L	<0.0005	<b>0.14</b>	MAC
Methyl tert-butyl ether	mg/L	<0.0005	<b>0.015</b>	AO
Styrene	mg/L	<0.0005		
Xylenes (total)	mg/L	<0.0005	<b>0.09</b>	MAC

1 - milligrams per litre (parts per million)

2 - microsiemens per centimeter

3 - Guidelines for Canadian Drinking Water Quality

4 - micrograms per litre (parts per billion)

### Acronyms

AO aesthetic objective

MAC maximum acceptable concentration

NTU nephelometric turbidity units

OG operational guidance value

TCU true colour units