

Chapman Creek Disinfection Bi-products (DBP) Test Results

1st Quarter 2022

Samples collected from the Chapman Creek Water System

						GCDWQ	
Trihalomethanes	Units	CH-01	CH-11	CH-14	CH-26	Limits	Type
Chloroform	mg/L	0.011	0.035	0.030	0.042		
Bromodichloromethane	mg/L	0.001	0.003	0.002	0.003		
Dibromochloromethane	mg/L	<0.001	<0.001	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.012	0.037	0.031	0.044	0.1¹	MAC
Haloacetic Acids							
Monochloroacetic Acid (MCAA)	ug/L	<2.0	<2.0	<2.0	2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	3.9	8.5	9.3	7.7		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	2.9	9.0	11.7	7.8		
Total Haloacetic Acids	ug/L	6.8	17.5	21.0	17.6	80¹	MAC

mg/L = Milligrams per Liter

GCDWQ - Guidelines for Canadian Drinking Water Quality

MAC = Maximim Acceptable Concentration

1 = Expressed as a running annual average

South Pender Disinfection Bi-products (DBP) Test Results

1st Quarter 2022

Samples collected from the South Pender Water System

					GCDWQ	
Trihalomethanes	Units	SP-09	SP-03	SP-06	Limits	Type
Chloroform	mg/L	0.032	0.043	0.050		
Bromodichloromethane	mg/L	0.002	0.003	0.003		
Dibromochloromethane	mg/L	<0.001	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.034	0.045	0.053	0.1¹	MAC
Haloacetic Acids						
Monochloroacetic Acid (MCAA)	ug/L	<2.0	2.0	2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	8.9	11.6	13.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	10.1	12.7	14.4		
Total Haloacetic Acids	ug/L	18.9	26.3	29.5	80¹	MAC

mg/L = Milligrams per Liter

GCDWQ - Guidelines for Canadian Drinking Water Quality

MAC = Maximim Acceptable Concentration

1 = Expressed as a running annual average

North Pender Disinfection Bi-prodcuts (DBP) Test Results

1st Quarter 2022

Samples collected from the North Pender Water System

				GCDWQ	
Trihalomethanes	Units	NP-07	NP-08	Limits	Type
Chloroform	mg/L	0.123	0.023		
Bromodichloromethane	mg/L	0.006	0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.128	0.025	0.1¹	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L	3.8	2.3		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	42.1	15.7		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	93.4	12.3		
Total Haloacetic Acids	ug/L	139.3	30.2	80¹	MAC

mg/L = Milligrams per Liter

GCDWQ - Guidelines for Canadian Drinking Water Quality

MAC = Maximim Acceptable Concentration

1 = Expressed as a running annual average

Ruby Lake Disinfection Bi-Products (DBP) Test Results

1st Quarter 2022

Samples collected from the Ruby Lake Water System

				GCDWQ	
Trihalomethanes	Units	RL-01	RL-03	Limits	Type
Chloroform	mg/L	0.055	0.079		
Bromodichloromethane	mg/L	0.004	0.005		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.060	0.084	0.1¹	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L	2.3	2.3		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	21.5	20.7		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	32.4	36.5		
Total Haloacetic Acids	ug/L	56.3	59.4	80¹	MAC

mg/L = Milligrams per Liter

GCDWQ - Guidelines for Canadian Drinking Water Quality

MAC = Maximim Acceptable Concentration

1 = Expressed as a running annual average

Egmont Disinfection Bi-products (DBP) Test Results

1st Quarter 2022

Samples collected from the Egmont Water System

				GCDWQ	
Trihalomethanes	Units	EG-01	EG-02	Limits	Type
Chloroform	mg/L	0.108	0.133		
Bromodichloromethane	mg/L	0.002	0.003		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	0.111	0.136	0.1¹	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L	2.4	2.9		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	24.7	44.1		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	64.3	93.8		
Total Haloacetic Acids	ug/L	91.3	140.7	80¹	MAC

mg/L = Milligrams per Liter

GCDWQ - Guidelines for Canadian Drinking Water Quality

MAC = Maximim Acceptable Concentration

1 = Expressed as a running annual average

Eastbourne Disinfection Bi-products (DBP) Test Results

1st Quarter 2022

Samples collected from the Eastbourne Water System

				GCDWQ	
Trihalomethanes	Units	20.1	20.3	Limits	Type
Chloroform	mg/L	0.003	0.006		
Bromodichloromethane	mg/L	0.003	0.006		
Dibromochloromethane	mg/L	0.003	0.004	0.016	MAC
Bromoform	mg/L	0.001	0.001		
Total Trihalomethanes	mg/L	0.009	0.017	0.1¹	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	2.40	3.80		
Bromochloroacetic Acid (BCAA)	ug/L	2.20	2.80		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	2.23	2.68		
Total Haloacetic Acids	ug/L	6.83	9.28	80¹	MAC

mg/L = Milligrams per Liter

GCDWQ - Guidelines for Canadian Drinking Water Quality

MAC = Maximim Acceptable Concentration

1 = Expressed as a running annual average

Langdale Disinfection Bi-products (DBP) Test Results

1st Quarter 2022

Samples collected from the Langdale Water System

				GCDWQ	
Trihalomethanes	Units	LA-01	LA-04	Limits	Type
Chloroform	mg/L	<0.001	0.001		
Bromodichloromethane	mg/L	<0.001	<0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	<0.001		
Total Trihalomethanes	mg/L	<0.001	0.001	0.1¹	MAC
Haloacetic Acids					
Monochloroacetic Acid (MCAA)	ug/L	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0		
Total Haloacetic Acids	ug/L	<12.0	<12.0	80¹	MAC

mg/L = Milligrams per Liter

GCDWQ - Guidelines for Canadian Drinking Water Quality

MAC = Maximim Acceptable Concentration

1 = Expressed as a running annual average

Soames Disinfection Bi-Products (DBP) Test Results

1st Quarter 2022

Samples collected from the Soames and Granthams Water Systems

					GCDWQ	
Trihalomethanes	Units	SO-01	SO-03	GL-02	Limits	Type
Chloroform	mg/L	<0.001	<0.001	<0.001		
Bromodichloromethane	mg/L	<0.001	<0.001	<0.001		
Dibromochloromethane	mg/L	<0.001	<0.001	<0.001	0.016	MAC
Bromoform	mg/L	<0.001	0.002	<0.001		
Total Trihalomethanes	mg/L	<0.001	0.002	<0.001	0.1¹	MAC
Haloacetic Acids						
Monochloroacetic Acid (MCAA)	ug/L	<2.0	<2.0	<2.0		
Monobromoacetic Acid (MBAA)	ug/L	<2.0	<2.0	<2.0		
Dichloroacetic Acid (DCAA)	ug/L	<2.0	<2.0	<2.0		
Bromochloroacetic Acid (BCAA)	ug/L	<2.0	<2.0	<2.0		
Dibromoacetic Acid (DBAA)	ug/L	<2.0	<2.0	<2.0		
Trichloroacetic Acid (TCAA)	ug/L	<2.0	<2.0	<2.0		
Total Haloacetic Acids	ug/L	<12.0	<12.0	<12.0	80¹	MAC

mg/L = Milligrams per Liter

GCDWQ - Guidelines for Canadian Drinking Water Quality

MAC = Maximim Acceptable Concentration

1 = Expressed as a running annual average