



SUNSHINE COAST REGIONAL DISTRICT

Question and Answers #2 Request for Proposal No. 2411602 Electrical Assessments for EV Chargers

Date: April 24, 2024

Item No. 1

Question: Regarding the networking hardware for either location, would you prefer to have the communications gateway (the hardware that takes in a cellular signal and emits a WIFI signal) mounted to the exterior of each building on a 120V power source or utilize a standalone gateway that is powered by tying into the 208V available powering up the charger and mounting onto the pedestal in the centre of the group of chargers?

Answer: Either option is acceptable.

Item No. 2

Question: Should the electrician require access to one or both sites prior to April 30th to inspect the area for installation purposes, who do we contact to arrange that?

Answer: The Regional District has already hosted a site meeting. Upon request, the Regional District may make another time available for all Proponents who wish to attend. Requests should be directed, in writing, to purchasing@scrd.ca.

Item No. 3

Question: Would you please confirm if the District is looking for a trade contractor (Electrical Contractor/General Contractor) or Engineering Consulting firm for this rfp?

Answer: The Regional District is looking for engineered design for this project.

Item No. 4

Question: We would like to request a one-week extension for this opportunity.

Answer: The Regional District would prefer to keep the existing closing date and not extend.