



**PACIFIC
POWERTECH** Inc.



Maintenance Report

SUNSHINE COAST REGIONAL DISTRICT

2023 - Electrical Maintenance and Testing

Location: Chapman Water Treatment Plant
5624 Reservoir Road, Sechelt, BC

Prepared For:

Robert Green
SUNSHINE COAST REGIONAL DISTRICT
5920 Mason Rd
Sechelt, BC V7Z 0N4

Date: February 10, 2023
Job No: 4561

Prepared By:

Jeroen Vandamme, NETA II
PACIFIC POWERTECH INC.
#110 – 2071 Kingsway Avenue
Port Coquitlam, BC V3C 6N2
Phone: 604.944.6697

Mobile: 604.861.4538
E-Mail: JVandamme@pacificpowertech.ca

COMMISSIONING • MAINTENANCE • ENGINEERING • SPECIALIZED ELECTRICAL SERVICES



☎ 604 944 6697 (24H)
🌐 pacificpowertech.ca

📍 110 - 2071 Kingsway Avenue
Port Coquitlam, BC V3C 6N2



Date: February 10, 2023

Job No: 4561

Attn: Robert Green

Subject: 2023 - Electrical Maintenance and Testing at Chapman Water Treatment Plant, Sechelt, BC

Dear Robert,

We are pleased to submit our report pertaining to the project noted above. The work was performed by Pacific Powertech field technicians Nikita Kanigan and Jeroen Vandamme. The work was completed in accordance with the shutdown schedule on January 30th, 2023 starting at 10:00hrs with power restoration at approximately 19:00hrs.

We trust this report will meet with your requirements. Should you require further information or assistance, please do not hesitate to contact us.

Thank you for retaining the services of Pacific Powertech Inc. We look forward to being of service to you in the future.

Regards,

PACIFIC POWERTECH INC.

Jeroen Vandamme, NETA II

Field Service Representative



Table of Contents

1. Maintenance Summary.....	4
2. Deficient Items	5
2.1. Fire Extinguisher	5
2.2. Loose Wiring	6
2.3. Single Line Diagram	7
2.4. Maturation Pump #1 Breaker Failure	8
3. General Recommendations.....	9
3.1. BC Hydro Maintenance Shutdown	9
3.2. Infrared Scan.....	9
3.3. Dirt Accumulation	9
Appendix A: Field Test Results.....	10
Appendix B: Safety Documentation.....	19

Table of Figures

Figure 1: Suggested Location of Fire Extinguisher Install	5
Figure 2: Loose C-phase Conductor Found Inside Cell 7E (Rooftop Unit RTU-1)	6
Figure 3: Failed Maturation Pump #1 Breaker	8



1. Maintenance Summary

The services of Pacific Powertech (PPI) were retained by Sunshine Coast Regional District to carry out maintenance and testing on the following electrical equipment at the Chapman Water Treatment Plant:

1. 600V Equipment:
 - MCC-A

The equipment listed above was maintained and tested in accordance with the NETA MTS 2019 standard. At this time, based on Pacific Powertech's analysis of the equipment inspection and test reports, the equipment within the scope of work is considered to be in satisfactory condition for service based on applicable standards (NETA, IEEE, and Manufacturer's Specifications). This excludes any items that have been noted as being deficient in Section 2 of this report. All equipment field test reports can be found in Appendix A of this report.

Section 2 of this report presents the deficient items noted during maintenance and outlines our recommendations to rectify these items.

2. Deficient Items

During the course of our service work, there were some items noted as being deficient and require further attention. Please review the deficiencies and recommendations presented in this section and contact us if you require further information.

2.1. Fire Extinguisher

It was noted that there was no fire extinguisher present in main electrical room where MCC-A is located.

Recommendation:

It is recommended that a properly rated fire extinguisher be permanently located in this area. It should be noted that an appropriate extinguishing agent be used for the application. Please consult your local fire inspector.




Figure 1: Suggested Location of Fire Extinguisher Install

2.2. Loose Wiring

During the course of our maintenance work, we noted several instances of loose wiring. We found one of the three phase conductors not properly terminated to the molded case circuit breaker inside the following MCC buckets:

- Cell 7E (Rooftop Unit RTU-1)
- Cell 9B (Make Up Air Unit MAU-2)
- Cell 9C (Air Compressor)

Recommendation:

We terminated all the loose wiring that we found during the maintenance outage. No further action is required.




Figure 2: Loose C-phase Conductor Found Inside Cell 7E (Rooftop Unit RTU-1)



2.3. Single Line Diagram

We noted that the single line diagram that was provided to us (drawing# E003 Rev. 2) did not fully match with the actual equipment installed in MCC-A. There are several MCC buckets that exist, but are not shown on the drawing. Vice versa, there are also buckets shown on the drawing that do not exist in reality. There are also several discrepancies between the breaker ratings & cable sizes shown on the drawing versus what is installed in reality.

Recommendation:

If drawing E003 Rev. 2 is in fact the most up-to-date single line diagram that exists for your facility, we recommend updating this drawing based on the information in this report. If you decide to go ahead with this recommendation, please feel free to contact us and we can provide you with a quote. We also forwarded all the cable information that was recorded on site to our engineering department, so that the arc flash hazard engineering study can be performed accurately.

2.4. Maturation Pump #1 Breaker Failure

The 50A breaker for "MP-3-1-01 Maturation Pump #1" (Cell 5B) was giving us very bad contact resistance results on C-phase. Upon operating this breaker several times in an attempt to improve these results, the breaker completely failed on C-phase and no longer had continuity. There was no replacement breaker present on site, so this pump was taken out of service temporarily until a replacement breaker is sourced.

Recommendation:

We recommend replacing this breaker and ordering additional breakers of several current ratings to keep as spares on site in case another breaker would fail in the future. **We also recommend replacing the 50A breaker for "MP-3-1-02 Maturation Pump #2" as this breaker was also returning bad contact resistance results.** We did not attempt to improve the results on this particular breaker to avoid a possible breaker failure like what happened to the Maturation Pump #1 breaker.

The failed breaker information is as follows:

- Brand: Eaton Cutler-Hammer
- Type: Series C Molded Case Circuit Breaker
- Category Number: HFD3050L
- Style Number: 3A16280G77




Figure 3: Failed Maturation Pump #1 Breaker



3. General Recommendations

3.1. BC Hydro Maintenance Shutdown

We were not able to service the main 1200A breaker, because the breaker itself was our lockout point for this maintenance shutdown.

Recommendation:

We recommend planning a full BC Hydro shutdown during the next scheduled maintenance outage, so that the main 1200A breaker and the pole transformers could also be serviced safely. Most likely, BC Hydro would isolate upstream from the high voltage pole disconnect switch that is owned by SCRD. In that case, this disconnect switch could also be included in the maintenance scope.

3.2. Infrared Scan

During the course of our maintenance work, we noticed several instances of loose wiring inside of MCC-A. Loose wiring can cause hot spots, which is a fire hazard. These hot spots can be detected by an infrared camera without the need of a power outage.

Recommendation:

We recommend performing an infrared scan that not only includes MCC-A, but also any electrical panels and disconnect switches spread throughout the facility. This is a service that Pacific Powertech offers. If you decide to go ahead with this recommendation, please feel free to contact us and we can provide you with a quote.

3.3. Dirt Accumulation

During the course of our maintenance work, we noticed a lot of dirt and dust accumulation inside MCC-A and the main electrical room as a whole. We cleaned every MCC bucket and vacuumed the electrical room.

Recommendation:

We recommend installing a filter on the air intake & exhaust manifolds of the electrical room to reduce future dirt & dust accumulation. We also recommend more frequent maintenance servicing.



Appendix A: Field Test Results

-Page Intentionally Blank-



MCC TEST FORM					
Job Number	4561			Date	30-Jan-23
Customer	Sunshine Coast Regional District			Test By	NK / JV
Location	Chapman Water Treatment Plant, Sechelt, BC			Approved By	Owen Kirby
NAMEPLATE DATA					
Designation	MCC-A	Rated Current	1200A Horizontal	BIL	Not Listed
Manufacturer	Allen-Bradley	Rated Current	300A Vertical	Brace (kA)	Not Listed
Type	Centerline BUL 2100	Rated Voltage	600V	No. of Sect.	13
Category Number	2100-ACT12-B2N-AAA-AAA	System	3 phase - 4 wire		
CELL DESIGNATION					
Cell No.	Designation	Rated Current (A)	Cable Size (AWG)	Protection Settings/Comments	
1A	BUS ACCESS	-	-		
1B	BC HYDRO METERING CELL	-	-		
1C	MCC-A MAIN 1200A BREAKER	1200A	-	LIVE CABLES NOT ACCESSIBLE	
2A	MCC-A TRANSFER SWITCH	600A	2x 4C 250 kcmil Cu		
3A	BWP-1-01 BACKWASH PUMP	250A	1x 3C #4 AWG Cu		
4A	SPARE	7A	-		
4B	DF-4-0-01 DUST COLLECTOR FAN	7A	1x 3C #10 AWG Cu	70ft	
4C	RV-4-1-01 SODA ASH BIN 1 ROTARY VALVE	7A	1x 3C #10 AWG Cu	70ft	
4D	RV-4-2-01 SODA ASH BIN 2 ROTARY VALVE	7A	1x 3C #10 AWG Cu	70ft	
4E	PDC-1 DISTRIBUTION PANEL	100A	1x 3C #2 AWG Cu		
4F	PDC-2 DISTRIBUTION PANEL	100A	1x 3C #2 AWG Cu		
5A	HWT-3	20A	1x 3C #12 AWG Cu	40ft	
5B	MP-3-1-01 MATURATION PUMP #1	50A	1x 3C #6 AWG Cu	NOTE 7	
5C	AB-3-1-01 AIR BLOWER #1	100A	1x 3C #2/0 AWG Cu		
6A	HWT-2	20A	1x 3C #12 AWG Cu	45ft	
6B	DRP-2-1-01 DAF RECYCLE PUMP #1	50A	1x 3C #6 AWG Cu		
6C	DRP-2-1-02 DAF RECYCLE PUMP #2	50A	1x 3C #6 AWG Cu		
6D	DRP-2-1-03 DAF RECYCLE PUMP #3	50A	1x 3C #6 AWG Cu		
6E	MP-3-1-02 MATURATION PUMP #2	50A	1x 3C #6 AWG Cu	NOTE 7	
7A	TRANSFORMER TRB BREAKER	30A	1x 3C #6 AWG Cu		
7B	TRANSFORMER TP-2 BREAKER	30A	1x 3C #6 AWG Cu		
7C	BCA SKID	30A	1x 3C #8 AWG Cu	500ft	
7D	HWT-1	20A	1x 3C #12 AWG Cu	65ft	
7E	ROOF TOP UNIT RTU-1	15A	1x 3C #10 AWG Cu	NOTE 4 / 400ft	
7F	SPARE	30A	-		
7G	EMPTY SPACE	-	-		
7H	EMPTY SPACE	-	-		

[illegible]



MCC TEST FORM - CELL LAYOUT									
SECTION 1		SECTION 2		SECTION 3		SECTION 4		SECTION 5	
1A	2A	3A	4A		5A				
1B			4B		5B				
			4C						
			4D						
			4E						
1C			4F		5C				
SECTION 6		SECTION 7		SECTION 8		SECTION 9		SECTION 10	
6A		7A		8A		9A	10A		
6B		7B		9B					
		7C		9C					
		7D		9D					
6C		7E		8B		9E	10B		
6D		7F		8C		9F		10C	
		7G							
6E		7H							

MCC TEST FORM - CELL LAYOUT (continued)

SECTION 11		SECTION 12		SECTION 13	
11A		12A		13A	
				13B	
				13C	
11B		12B		13D	
11C		12C		13E	
		12D		13F	



MCC TEST FORM

CONTACT RESISTANCE TESTS

From Cell #	To Cell #	Phase A	Phase B	Phase C	Test Current	10A DC
					Comments	
CLOSED BREAKER MEASUREMENTS IN EVERY CELL						
2A	2A	94	82	101	TRANSFER SWITCH - NORMAL	
2A	2A	136	153	184	TRANSFER SWITCH - GENERATOR	
3A	3A	564	160	200	NOTE 8	
4A	4A	-	-	-	BREAKER TOO SMALL TO TEST	
4B	4B	-	-	-	BREAKER TOO SMALL TO TEST	
4C	4C	-	-	-	BREAKER TOO SMALL TO TEST	
4D	4D	-	-	-	BREAKER TOO SMALL TO TEST	
4E	4E	1620	670	750		
4F	4F	964	1240	1210		
5A	5A	-	-	-	NOT ACCESSIBLE	
5B	5B	4431	8040	-	BREAKER FAILED DURING TESTING (NOTE 7)	
5C	5C	1041	550	5880	NOTE 8	
6A	6A	-	-	-	NOT ACCESSIBLE	
6B	6B	4185	2700	3330		
6C	6C	3678	1250	5650		
6D	6D	1048	1470	6740		
6E	6E	16330	11460	43960	RECOMMEND REPLACE BREAKER (NOTE 7)	
7A	7A	4390	2980	4090		
7B	7B	3510	3880	2930		
7C	7C	5090	2540	6820		
7D	7D	-	-	-	NOT ACCESSIBLE	
7E	7E	32910	25540	14040		
7F	7F	59840	15810	118560	SPARE BREAKER - NOT IN USE	
7G	7G	-	-	-	EMPTY SPACE	
7H	7H	-	-	-	EMPTY SPACE	
8A	8A	158800	172070	221360	SPARE BREAKER - NOT IN USE	
8B	8B	1500	790	2200		
8C	8C	1600	420	2000		
9A	9A	3840	3500	6280		
9B	9B	9970	3890	20150		
9C	9C	2950	3240	2630		
9D	9D	16720	27890	19450		
9E	9E	15880	11620	17470		
9F	9F	17460	10240	11930		

*Results in Micro Ohms



MCC TEST FORM

CONTACT RESISTANCE TESTS (continued)

From Cell #	To Cell #	Phase A	Phase B	Phase C	Test Current	10A DC
Comments						
CLOSED BREAKER MEASUREMENTS IN EVERY CELL (continued)						
10A	10A	-	-	-		LIGHTING PANEL
10B	10B	1600	1560	1390		
10C	10C	-	-	-		TRANSFORMER
11A	11A	-	-	-		LIGHTING PANEL
11B	11B	6610	2630	4630		
11C	11C	-	-	-		TRANSFORMER
12A	12A	-	-	-		FUTURE LIGHTING PANEL
12B	12B	-	-	-		EMPTY SPACE
12C	12C	-	-	-		EMPTY SPACE
12D	12D	-	-	-		EMPTY SPACE
13A	13A	-	-	-		EMPTY SPACE
13B	13B	-	-	-		EMPTY SPACE
13C	13C	-	-	-		EMPTY SPACE
13D	13D	-	-	-		EMPTY SPACE
13E	13E	-	-	-		EMPTY SPACE
13F	13F	-	-	-		EMPTY SPACE
FROM LOAD SIDE OF BC HYDRO METERING TO LINE SIDE OF TRANSFER SWITCH NORMAL POWER						
1A	2A	101	111	122		
FROM LOAD SIDE OF TRANSFER SWITCH TO LINE SIDE OF EVERY CELL						
2A	3A	996	1080	1280		
2A	4A	1282	840	1880		
2A	4B	1375	1110	1550		
2A	4C	1037	790	1230		
2A	4D	1106	800	1270		
2A	4E	526	400	550		
2A	4F	625	460	600		
2A	5A	8990	12040	9300		MEASURED TO LOAD SIDE
2A	5B	1049	830	1100		
2A	5C	599	550	680		
2A	6A	10980	9380	12240		MEASURED TO LOAD SIDE
2A	6B	875	760	980		
2A	6C	1102	1020	1050		
2A	6D	747	700	990		
2A	6E	1200	940	1240		
2A	7A	1990	1910	2660		
2A	7B	1980	2120	2570		
2A	7C	2240	2050	6150		NOTE 8
2A	7D	11670	9480	11330		MEASURED TO LOAD SIDE

*Results in Micro Ohms



CONTACT RESISTANCE TESTS (continued)

*Results in Micro Ohms



MCC TEST FORM

INSULATION TESTS

Temperature (°C)	8	Humidity (%)	69			
Test Description	Voltage	Time	Phase A	Phase B	Phase C	
NOT ABLE TO ISOLATE MCC BUS FOR TESTING DUE TO BC HYDRO METERING CONNECTIONS						

Results In: Giga Ohms

INSPECTION CHECK LIST

Description	Pass	Fail	N/A	Comments
Push Buttons			X	No push buttons present on this MCC
Indicator Lamps	X			Most are not connected
Isolator Handles & Interlocks	X			All handles & interlocks function as designed
Signs of Stress or Overheating	X			No signs of stress or overheating
Starter Contacts	X			No signs of wear; cleaned
Bolted Connections	X			Verified via contact resistance testing
Cables & Wire Terminations	X			All cables & wires checked for tightness. NOTE 4
Power Fuses/Control Fuses	X			All power & control fuses checked for continuity
Dirt Accumulation	X			Found very dirty. Cleaned & vacuumed. NOTE 5
Breaker/Contactor Function Test	X			All breakers & contactors operated as designed
Grounding	X			Verified via contact resistance testing
Moisture/Corrosion	X			None visible upon inspection
Barriers/Insulators	X			Visually inspected & cleaned; No signs of damage
Equipment Matches Drawing		X		MCC does not exactly match provided drawing
Panel Meters	X			Verified before and after maintenance outage
Instrument Transformers	X			Cleaned & verified via panel metering

NOTES

NOTE 1: We recommend a full BC Hydro shutdown during the next scheduled maintenance outage so that the main 1200A breaker and possibly the upstream pole disconnect switch could also be included in the maintenance scope.

NOTE 2: There is no fire extinguisher installed in the electrical room. Recommend installing one.

NOTE 3: We recommend performing an infrared scan of all the electrical equipment in this plant while it is up and running under normal load.

NOTE 4: In this cell we found one of the three phase conductors not properly terminated to the breaker. We terminated this conductor. No further action required.

NOTE 5: MCC was found very dirty. We recommend installing a filter on the air intake & exhaust manifolds of the electrical room. We also recommend more frequent maintenance servicing.

NOTE 6: This MCC does not match exactly with the single line drawing that was provided to us (DWG# E003 Rev. 2). There are several MCC buckets that exist, but are not shown on the drawing. Vice versa, there are also buckets shown on the drawing that do not exist in reality. There are also several discrepancies between the breaker ratings & cable sizes shown on the drawing versus what is installed in reality. Recommend updating single line drawing based on the information in this test sheet.

NOTE 7: The 50A breaker for "Maturation Pump #1" was giving us very bad contact resistance results on C-phase. Upon operating this breaker several times in an attempt to improve these results, the breaker completely failed on C-phase and no longer has continuity. There was no replacement breaker present on site, so this pump was taken out of service temporarily until a replacement breaker is sourced. We also recommend replacing the 50A "Maturation Pump #2" breaker as it is also returning bad contact resistance results.

NOTE 8: Recommend allotting extra time during the next outage to attempt improving the contact resistance results of



Appendix B: Safety Documentation

-Page Intentionally Blank-



#110-2071 Kingsway Avenue
Port Coquitlam, BC V3C 6N2
Phone: 604-944-6697 (24HR)
www.pacificpowertech.ca



SITE SAFETY MEETING

SITE SAFETY MEETING			
Job Number	4561	Date	JAN 30, 2022
Customer	SCRD	Presented By	NK
Location	CHAPMAN WTP, 5624 RESERVOIR RD	Revision	9.1 (Mar, 2022)

ATTENDEES					
Name	Initial	Name	Initial	Name	Initial
NIKITA KANIGAN	NK				
JERDEN VAN D.	J.V.				
ROBERT GREEN	RG				

Safety Equipment Used:

Safety Clearance Certificate Used:

Isolation Methods Used:

Specific Items Discussed prior to Work:

<input checked="" type="checkbox"/>	Pacific Powertech Safety / OH&S manuals on hand	
<input checked="" type="checkbox"/>	Voltage dectectors	
<input checked="" type="checkbox"/>	Nomex coveralls, hard hat, safety shoes, safety glasses	
<input checked="" type="checkbox"/>	Arc flash suit and hood during switching & grounding	
<input checked="" type="checkbox"/>	# of High Voltage Safe Work Grounds Used	1
<input checked="" type="checkbox"/>	High voltage gloves - class	3
<input checked="" type="checkbox"/>	Pacific Powertech	
<input type="checkbox"/>	Customer	
<input type="checkbox"/>	Utility: GOI / Customer Isolation	
<input type="checkbox"/>	Safety Clearance not required	
<input checked="" type="checkbox"/>	Visual	
<input checked="" type="checkbox"/>	Lockout and Tag	
<input type="checkbox"/>	Hot work required & specific written procedure in place	
<input checked="" type="checkbox"/>	Review SLD & confirm points of isolation & grounding to all workers	
<input checked="" type="checkbox"/>	Walk around equipment & identify hazards (energized equipment)	
<input checked="" type="checkbox"/>	Install safety barriers/flagging to energized equipment in work zone	
<input checked="" type="checkbox"/>	Exposure to sharp & hot objects has been discussed	
<input checked="" type="checkbox"/>	Site hazard assessment: falling objects, chemicals, dust	
<input checked="" type="checkbox"/>	Review requirement for ventilation	
<input checked="" type="checkbox"/>	Location of fire extinguishers, eyewash & first aid station	
<input checked="" type="checkbox"/>	Emergency contact numbers/procedure (911)	
<input type="checkbox"/>	Other:	
<input checked="" type="checkbox"/>	Nearest hospital: SEACHELT Hospital	
<input checked="" type="checkbox"/>	Authorized personnel only in work/testing areas	
<input checked="" type="checkbox"/>	Emergency power backfeed potential reviewed/discussed (Genset/UPS)	
<input checked="" type="checkbox"/>	Equipment arc flash labels have been reviewed prior to any switching	
<input checked="" type="checkbox"/>	Ensure all utility feeders to transfer switches are included in lockout	
<input checked="" type="checkbox"/>	Identify possible back feeds from control circuits	
<input checked="" type="checkbox"/>	Open communication policy - "if in doubt ask"	
<input checked="" type="checkbox"/>	Power tools	
<input checked="" type="checkbox"/>	Emergency lighting	
<input checked="" type="checkbox"/>	Access/Egress	
<input checked="" type="checkbox"/>	Anticipate power back at:	16:00
<input checked="" type="checkbox"/>	Test before touch policy	



SITE SAFETY MEETING

Cautions/Concerns During Outage:

- ☒ All switches to be noted and reset to "As Found" condition
- ☒ Transformer XO ground bond location has been verified
- NOTE: Refer to dry-type transformer SWP for isolation of XO ground bond*
- ☒ Tools, test jumpers and rags - keep count and do not set down inside or on the electrical equipment
- ☒ Discuss concern surrounding Asbestos containing materials (PPE)
- ☒ Discuss caution with loaded springs and hazardous mechanisms
- ☒ Review requirements for megger/hipot testing
- ☒ Refer to NETA Standards for equipment testing procedures
- ☒ All equipment included in scope of work must be tested for absence of potential prior to issuance of SWC.
- ☒ Discuss with owner any other work that is taking place outside of our defined scope of work
- ☒ Discuss with crew concerns surrounded heat exhaustion and the importance of staying hydrated
- ☒ Person disconnecting cables is responsible to reconnect cables prior to signing off Safe Work Clearance
- ☒ Second person must inspect switchgear prior to installing covers
- ☐ Designated Electrical Safety Watch (ESW): _____

Additional Site Specific Items:


Scope of Work General Description:

MCC-A TESTING

Hazard Assessment

Hazard	Mitigation Methods
ARC FLASH	FLASH SUIT DURING SWITCHING & GROUNDING
SHOCK	TEST BEFORE TOUCH

ALWAYS REMEMBER - TEST BEFORE YOU TOUCH!!


Pacific Powertech Inc.

JAN 30, 2023
Date



SAFE WORK CLEARANCE CERTIFICATE			
Job Number	4561	Date	JAN 30, 2022
Customer	SCRD	Clearance #	
Location	CHAPMAN WTP, 5624 BESENER RD	Revision	11.0 - May/2022
Job Description	MCC TESTING, DATA GATHERING		
PART I - SECTION A : ISSUE OF CLEARANCE (To Be Completed By The Person Switching To Achieve Isolation)			
Issuer:	NIKIYA K.	Signed:	
		Date:	JAN 30, 2022
		Time:	10:30
Safety Watch:	JEROEN V.	Recipient:	JEROEN V.
LIST OF EQUIPMENT CLEARED FOR SERVICE			
①	600V MCC		
ISOLATION POINTS			
Isolation Points		By	Verified
①	600V MAIN BREAKER	PPI	JV
②	GENERATOR DISCONNECT	PPI	JV
BC Hydro SPG #:		For Work On Circuit #	
SAFE WORK GROUND LOCATIONS			
①	LOAD SIDE MAIN BREAKER		
NOTES			



SAFE WORK CLEARANCE CERTIFICATE

PART I - SECTION B : ISSUE OF CLEARANCE (To Be Completed By Recipient / Safety Watch)

Reason For Work: MCC TESTING

The isolation points, location of grounding and extent of work have been thoroughly discussed with the following:

	Name	Signature		Name	Signature
1	NIKITA K.		11		
2	JEROEN V.		12		
3			13		
4			14		
5			15		
6			16		
7			17		
8			18		
9			19		
10			20		

I am satisfied with the clearance provided and that all dangerous locations are secure from access by unauthorized personnel and equipment has been tested for ABSENCE OF POTENTIAL.

THIS SAFE WORK CLEARANCE IS IN EFFECT AT 10 : 50 HRS

Signed:

(Recipient / Safety Watch)

Date: JAN 30, 2023

PART II - SECTION C : SURRENDER OF CLEARANCE

WORKER SIGN-OFF. (BY SIGNING HERE YOU HAVE STATED THAT WORK IS COMPLETE AND THE EQUIPMENT IS TO BE TREATED AS ENERGIZED)

	Name	Signature		Name	Signature
1	NIKITA K		11		
2	Jeroen Vanlaere		12		
3			13		
4			14		
5			15		
6			16		
7			17		
8			18		
9			19		
10			20		

CLEARANCE TERMINATION CHECKLIST (COMPLETED BY RECIPIENT)

- ☒ All work on equipment has ceased.
- ☒ All tools and test leads are removed and accounted for.
- ☒ All working grounds have been removed and visually accounted for. No. of Sets: 7
- ☒ All control and power fuses have been returned to the operating state.
- ☒ Equipment checklist is complete and the equipment is ready for energization.
- ☒ All personnel have been informed of equipment status and are to stay CLEAR prior to energization

I have SURRENDERED this SAFE WORK CLEARANCE by my signature and request issuer to complete the verification in Section D below.

THIS SAFE WORK CLEARANCE IS TERMINATED AT 17 : 20 HRS Date: JAN 30, 2023

PART III - SECTION D : VERIFICATION OF CLEARANCE (Must Be Completed By Issuer Prior To Power Restoration)

- ☒ I have read, reviewed and verified the foregoing Part II (Section C)
- ☒ All tools and test leads are removed and accounted for.
- ☒ All working grounds have been removed and visually accounted for. No. of Sets: 1
- ☒ Equipment checklist is complete and the equipment is ready for energization.

SURRENDER OF CLEARANCE IS VERIFIED AND ACCEPTED AT 17 : 25 HRS

Signed:

(Issuer)

Date: JAN 30, 2023