



# SUNSHINE COAST REGIONAL DISTRICT

Question and Answers #1

Request for Proposal No. 2461301

Engineered Air Roof Top Unit Replacement

**Date: February 13, 2024**

## **Item No.1 Roofing & Curbs**

**Question:** The drawings indicate the old RTU to be removed and the existing curb to remain and be reused, however, the new unit is shown to be installed with a new curb in another location. Could you please confirm if the old curb is indeed to remain? How shall it be made good?

**Answer:** Contractor to infill and cap the existing roof curb. Ensure weatherproofed & watertight.

---